Certificate of Accreditation

UKAS United Kingdom Accreditation Service

Water Hygiene Centre Ltd

Inspection Body No. 7826

is accredited as a Type C body in accordance with International Standard ISO/IEC 17020:2012 - Conformity assessment – Requirements for the operation of various types of bodies performing inspection

This accreditation demonstrates technical competence for a defined scope specified in the schedule to this certificate, and the operation of a management system (refer joint ISO-ILAC-IAF Communiqué dated September 2013). The schedule to this certificate is an essential accreditation document and from time to time may be revised and reissued.

The most recent issue of the schedule of accreditation, which bears the same accreditation number as this certificate, is available from www.ukas.com.

This accreditation is subject to continuing conformity with United Kingdom Accreditation Service requirements.

Matt Gantley, *Chief Executive Officer*
United Kingdom Accreditation Service

Initial Accreditation: 13 April 2015
Certificate Issued: 25 January 2024

ilac-MRA

UKAS United Kingdom Accreditation Service

Scan QR Code to verify

UKAS is appointed as the sole national accreditation body for the UK by The Accreditation Regulations 2009 (SI No 3155/2009) and operates under a Memorandum of Understanding (MoU) with the Department for Business and Trade (DBT).

Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

7826

Type C Inspection Body

Accredited to ISO/IEC 17020:2012

Water Hygiene Centre Ltd

Issue No: 011 **Issue date:** 05 January 2026

6-7 Southill Business Park
Cornbury Park
Charlbury
Oxfordshire
OX7 3EW

Contact: Mr Chris Lawry
Tel: +44 (0)1993 840400
E-Mail: Chris.Lawry@waterhygienecentre.com
Website: www.waterhygienecentre.com

Inspection performed at/from the above location only

DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures
Legionella Risk Assessments (including health and social care settings)	Artificial water risk system: • Hot/cold systems • Spa baths and hydrotherapy pools • Other systems containing water which is likely to exceed 20°C which may release a spray or aerosol during operation or when being maintained	Documented In-House Methods, based on the requirements of ACoP L8 and BS 8580-1:2019 In house method 1 (PDSRAP01)
	Water testing for the purpose of Legionella risk assessment: • Temperature Testing may be reported only as part of a risk assessment report in support of the Legionella risk assessment.	In house method 3 (PDSHCP01)
END		